



Pierce County Fire District 21

PO Box 369 • Graham WA 98338 • (253) 847-8811 • FAX (253) 847-2233

Gerald W. Gustafson
Commissioner

Russell T. Barstow
Commissioner

Adam G. Rosenlund
Commissioner

Gina Blanchard-Reed
Commissioner

Ryan Portmann
Commissioner

Pat Dale
Fire Chief

RESOLUTION NO. 914

A RESOLUTION OF THE BOARD OF FIRE COMMISSIONERS FOR PIERCE COUNTY FIRE PROTECTION DISTRICT NO. 21 DECLARING CERTAIN ITEMS SURPLUS TO THE NEEDS OF THE DISTRICT.


WHEREAS: The items listed on Attachment "A" have been deemed surplus to the needs of the District due to age, condition and/or not repairable; and,

WHEREAS: The Board of Fire Commissioners has the authority to declare items surplus to the needs of the District.


THEREFORE, BE IT RESOLVED BY THE BOARD OF FIRE COMMISSIONERS FOR PIERCE COUNTY FIRE PROTECTION DISTRICT NO. 21 THAT:

Section 1. The items listed on Attachment "A" be declared surplus to the needs of the District. All items will be surplused at zero value and disposed of properly.


MOVED AND PASSED AT A REGULAR MEETING OF THE BOARD OF FIRE COMMISSIONERS FOR PIERCE COUNTY FIRE PROTECTION DISTRICT NO. 21 ON NOVEMBER 14, 2018, OF WHICH ALL COMMISSIONERS WERE NOTIFIED AND THE FOLLOWING WERE PRESENT AND VOTING:




Ryan Portmann, Board Chairman



Adam G. Rosenlund, Commissioner




Gerald W. Gustafson, Commissioner



Gina Blanchard-Reed, Commissioner

ATTEST:

Russell T. Barstow, Commissioner



Anthony D. Judd, District Secretary

SURPLUS REPORT - ARMORY - 11/6/2018

QTY	Asset Description	Asset Tag Number	Serial Number	Decommission/ Out-of-Service Date	Notes
1	Bunker Coat, G-Xtreme, 40x32	3292253	3292253	12/1/2016	Out of 10-year NFPA Standard. Damaged beyond reasonable repair.
1	Bunker Coat, G-Xtreme, 40x32	3661654	3661654	3/31/2017	Beyond NFPA Standard. Velcro is damaged. Hole in right elbow.
1	Bunker Coat, G-Xtreme, 40x32	3835803	3835803	5/1/2019	Failed inspection; liner compromised.
1	Bunker Coat, G-Xtreme, 42x32	3175433	3175433	6/1/2016	Garment is beyond NFPA Standard. Covered in red paint.
1	Bunker Coat, G-Xtreme, 42x32	3341563	3341563	2/28/2017	Out of 10-year NFPA Compliance. Damaged beyond reasonable repair.
1	Bunker Coat, G-Xtreme, 42x32	3455159	3455159	9/30/2017	Out of 10-year NFPA Standard. Gear contaminated with oil.
1	Bunker Coat, G-Xtreme, 42x32	3660894	3660894	7/31/2018	Out of 10-year NFPA Standard. Inner liner ripped.
1	Bunker Coat, G-Xtreme, 42x32	4105362	4105362	10/1/2020	Seam tape failed. Not economical to repair due to age.
1	Bunker Coat, G-Xtreme, 42x32 OS	3455152	3455152	9/1/2017	Taken out of service by NWSC on 2/18/2018. Out of 10-year NFPA Standard.
1	Bunker Coat, G-Xtreme, 42x32, NO DRD	3455156	3455156	9/30/2017	Out of 10-year NFPA Standard. Rip in right shoulder.
1	Bunker Coat, G-Xtreme, 44x32	03455161	03455161	5/1/2017	Beyond NFPA 10-year standard. Ripped liner and shell.
1	Bunker Coat, G-Xtreme, 44x32	3313144	3313144	1/1/2017	Out of 10-year NFPA Standard. Rip in right shoulder.
1	Bunker Coat, G-Xtreme, 46x30	3835820	3835820	7/31/2018	Failed inspection; liner compromised.
1	Bunker Coat, G-Xtreme, 46x32	3313150	3313150	1/31/2017	Out of 10-year NFPA Standard. Damaged beyond reasonable repair.
1	Bunker Coat, G-Xtreme, 46x32	3660915	3660915	7/1/2018	Out of 10-year NFPA Standard. Rip in front right pocket.
1	Bunker Coat, G-Xtreme, 46x32	3835817	3835817	7/31/2019	Failed inspection; liner compromised.
1	Trouser, 34x30	03455168	03455168	9/1/2017	Out of 10-year NFPA Standard. Rip in left knee.
1	Trouser, 34X30	3085936	3085936	5/1/2019	Rips in both knees. Liner failed inspection by NWSC in 2018.
1	Trouser, 36x30	3292261	3292261	12/31/2016	Out of 10-year NFPA Standard. Missing liner.
1	Trouser, 36x30	3355685	3355685	3/31/2017	Out of 10-year NFPA Standard. Missing liner.
1	Trouser, 36x30	3660943	3660943	7/1/2018	Out of 10-year NFPA Standard. Left knee tear.

SURPLUS REPORT - ARMORY - 11/6/2018

QTY	Asset Description	Asset Tag Number	Serial Number	Decommission/ Out-of-Service Date	Notes
1	Trouser, 36X30, OS	03660949	03660949	7/31/2018	Taken out of service on 2/18/2018 by NWSC. Out of 10-year NFPA Standard. Tear in right pocket and right knee.
1	Trouser, 36x32	3455183	3455183	9/1/2017	Out of 10-year NFPA Standard. Ripped right knee.
1	Trouser, 38x30	03732284	03732284	1/1/2017	Out of 10-year NFPA Standard. Liner failed inspection.
1	Trouser, 38X30	3313163	3313163	1/1/2017	Out of 10-year NFPA Standard. Missing shell.
1	Trouser, 38X30	3660955	3660955	7/1/2018	Out of NFPA 10-year standard; Damaged beyond reasonable repair.
1	Trouser, 38x30	3660957	3660957	7/1/2018	Beyond NFPA Standard Life. Missing liner, ripped shoulder.
1	Trouser, 38x30	3660960	3660960	7/1/2018	Out of 10-year NFPA Standard. Tear in right knee.
1	Trouser, 38X30	3835853	3835853	5/31/2019	Failed test; liner compromised.
1	Trouser, 38X30	3835854	3835854	5/1/2019	Taken out of service by NWSC. Liner failed inspection.
1	Trouser, 38x30	3835858	3835858	7/1/2018	Failed test; liner compromised.
1	Trouser, 38x32	3320216	3320216	5/1/2017	Missing Shell. Beyond 10-year NFPA Standard.
1	Trouser, 38x32, OS	04219874	04219874	5/1/2021	Taken out of service on 2/18/2018 by NWSC because of liner failure. Rip in right knee.
1	Trouser, 38X34	3660981	3660981	7/1/2018	Out of 10-year NFPA Compliance. Rip in left knee.
1	Trouser, 40X30	03232623	03232623	9/1/2016	Out of 10-year NFPA Compliance. Rip in right knee.
1	Trouser, 40X30	3202632	3202632	8/31/2016	Out of 10-year NFPA Compliance. Rip in right knee.
1	Trouser, 40x32, OS	03196474	03196474	8/1/2016	Taken out of service by NWSC on 2/18/2018. Out of 10-year NFPA Standard. Tears in both knees.