



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501

November 11 2021
Addendum 2
Request for Quote # 21-38-209332
Whittier CP040 Switch Heat Power Upgrade

This addendum is being issued to provide information as follows: THE CLOSING DATE FOR THIS SOLICITATION HAS CHANGED AS FOLLOWS, BIDS WILL BE RECEIVED UNTIL 3:00 PM LOCAL TIME ON, NOVEMBER 23, 2021

BID INFORMATION, CONDITIONS & INSTRUCTIONS:

Closing date changed to November 23, 2021.

STATEMENT OF WORK - ADDITIONS:

After the pre-bid site visit, the ARRC would like to add or clarify the following items to the Statement of Work

- Contractor shall pull ARRC provided fiber from the telecom room up and into the CP. The SOW call for an empty conduit that ARRC would use at a later date, the contractor will now pull that cable instead of ARRC
- Contractor can supply and install any brand of check meter they want as long as it is in a weather proof enclosure where it can be read at any time by Tunnel Control. The meter should capture the total power consumed by the heater and both huts.
- The contractors proposal should include a description or drawing of the routing of the proposed conduit runs from the panel inside the tunnel to the CP.

Please acknowledge receipt of this and all addendums in your firm's **Construction Bid Form (Form 395-0121)**. **All other dates, terms and conditions remain unchanged.**

Please direct all responses and/or questions concerning this solicitation to Timothy Bates, Alaska Railroad Corporation, Contracts, 327 Ship Creek Avenue, Second Floor, Anchorage, AK 99501, telephone number 907-265-2355, fax number 907-265-2439 or at email address BatesT@akrr.com .

Sincerely,

Timothy Bates
Timothy Bates
Contract Administrator
Alaska Railroad Corporation