



## ALASKA RAILROAD CORPORATION

327 W. SHIP CREEK AVENUE

ANCHORAGE, AK 99501

[THOMPSONC@AKRR.COM](mailto:THOMPSONC@AKRR.COM)

PHONE 907.265.2068

CELL 907.854.3141

June 17, 2024

### Addendum 2

Request for Quote 24-43-212189

BR 63.0 Install Headache Beam

Addendum number 2 has been issued for questions/clarification.

**Offers will now be received until 3:00 pm local time on June 20, 2024.**

---

### Question(s)

1. Are the shop welds D1.5 and field welds D1.1?  
**All welds, on this, shop or field are D1.1.**
  2. Could you confirm RR Protective and Builders Risk is not required on this project?  
**Railroad Protective is required, Builders Risk insurance is not required.**
- 

All other terms and conditions remain unchanged.  
If there are any questions regarding this addendum, please let me know.

Thank you,

*C. Lee Thompson*

Contract Administrator  
Alaska Railroad Corporation