



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501.

April 20, 2020

Addendum 2

RFQ #20-208108

Demolition of 70,000 Gallon Above Ground Storage Tank

Addendum number 2 is issued for Questions / Clarifications.

The Closing Date for this has changed. This ITB will close as follows:
Proposals will be received until April 23, 2020 @ 3:00 PM local Alaska time.

Questions /Clarifications:

1. Will there be any soil that will be required to be moved off the property?
No, we anticipate some contaminated soil but it will not need to be removed, just graded level.
2. Will you quantify the estimated amount of residual fuel in the tank to be cleaned out?
For bidding purposes, we would estimate there to be 200 gallons of fuel/residual left in the tank.
3. Will flagging protection be provided?
Yes, ARRC will provide flagging protection for the project.

The electrical will be disconnected by ARRC prior to any work scheduled to begin.

All other terms and conditions remain unchanged.
If there are any questions regarding this addendum please let me know.

Thank you,

Greg Goemer
Sr. Contract Administrator
Alaska Railroad Corporation