



DETAIL 2  
1/2" DIA (6 THRU) 6'-0"

- NOTES:**
1. REFER TO DWG 61 FOR GENERAL CONCRETE NOTES.
  2. ALL CONCRETE TO HAVE MINIMUM 4,000 psi COMPRESSIVE STRENGTH IN 28 DAYS.
  3. ALL REINFORCING STEEL TO BE A65 GRADE 60 (Fy=60,000 psi) DEFORMED REINFORCING STEEL.
  4. REINFORCING COVE TO BE @ 0' SIDES & BOTTOM, @ 0' TOP.
  5. ALL DESIGN, REINFORCING & PLACEMENT OF REINFORCING STEEL TO FOLLOW THE CODES & GOOD PRACTICES OF THE FOLLOWING CODE REQUIREMENTS FOR REINFORCED CONCRETE:
    - a. THE AMERICAN CONCRETE INSTITUTE'S MANUAL OF STANDARD PRACTICES FOR THE CONCRETE REINFORCING INDUSTRY.

DATE		DATE	
DATE		DATE	
DATE		DATE	GENERAL REVISIONS
DATE		DATE	ORIGINAL ISSUE

*Alan D. Anderson*

DATE	7-20-81		<b>PLAN &amp; DETAILS</b> <b>FILTER FOUNDATION</b>		PLAN	REVISION
SCALE	NOTED		3052	2		
DRAWN BY	DE		SHEET NO. 3052 SHEET 2			
CHKD BY	DE		KIBOOR ENGINEERING COMPANY ALBUQUERQUE, NEW MEXICO			
APPRD BY	AEP	3660 09	<b>C6</b>			
PRINTED						