



Alaska Railroad Corporation  
327 W. Ship Creek Ave.  
Anchorage, AK 99501

March 21, 2022

Addendum 1  
ITB #22-22-209666  
2022 Spiralweld 36" Culvert

**Addendum number 1 has been issued for questions.**

The Closing Date for this ITB has not changed.  
Bids will be received until March 31, 2022 @ 3:00 PM Alaska time.

---

**Questions:**

1. Will ARRC accept good used buy back pipe?  
**Yes. The following stipulations must be met.**
  1. The heat number stamped on the pipe is visible and matches the MTR
  2. The pipes physical characteristics do not show signs of yielding from being overstressed from its previous use (not bowed, bent, dented or oblong openings).
  3. The pipe doesn't have remnants of steel welded to it from its previous use that would interfere with ARRC's handling and installation, unless approved.
  4. Meets Buy America requirement.

All other terms and conditions remain unchanged.  
If there are any questions regarding this addendum please let me know.

Thank you,

*Rob Walker*  
Contract Administrator  
Alaska Railroad Corporation