



Alaska Railroad Corporation  
327 W. Ship Creek Ave.  
Anchorage, AK 99501

May 8, 2023

Addendum 2  
ITB #23-31-210701  
Fabrication and Supply of 26' I-Beam Bridge Span

Addendum number 2 has been issued for questions.

**The Closing Date for this ITB has not changed.**

**Bids will be received until May11, 2023 @ 3:00 PM Alaska time.**

---

**Questions:**

1. Page 19, regarding NDE requirements, calls for the groove welds on the bottom of the Pier Cap shall be 100% RT inspected. To RT you need access to both sides of the welds. This is not possible. We request substituting 100% UT in lieu of RT.  
**A. The use of UT in lieu of RT on the Pier Cap is acceptable.**

All other terms and conditions remain unchanged.

If there are any questions regarding this addendum please let me know.

Thank you,

***Greg C Goemer***

Sr. Contract Administrator  
Alaska Railroad Corporation