



Alaska Railroad Corporation
327 W. Ship Creek Ave.
Anchorage, AK 99501

October 17, 2023

Addendum 3

ITB #23-53-211209

Seattle Terminal Electrical Repairs

Addendum number 3 has been issued for questions/ clarification.

The Closing Date for this ITB has not changed.

Bids will be received until October 26, 2023 @ 3:00 PM Alaska time.

Questions:

1. Does ARRC want the transformer in the electrical building to be provided with a stainless-steel housing to match other equipment? Other enclosures are specified as stainless.
 - A. **Please add the following to 'General Notes', Sheet E1.00: "5. Electrical enclosures for motor starters, panel P1, meter enclosure, and transformers (T1 & T2), shall be stainless steel. All other requirements apply."**

All other terms and conditions remain unchanged.

If there are any questions regarding this addendum please let me know.

Thank you,

Greg C Goemer

Sr. Contract Administrator
Alaska Railroad Corporation