



ALASKA RAILROAD CORPORATION
327 W. Ship Creek Ave.
Anchorage, AK 99501.

January 21, 2019

Addendum 2

ITB # 19-01-207065

Sheet Pile Retaining wall for West 1st Ave Extension

Addendum number 2 is issued for additional questions

**The Closing Date for this has not changed. This ITB will close as follows:
Bids will be received until Friday January 25, 2018 @ 3:00 PM local Alaska time.**

Questions:

- 1) Will the ARRC accept ZZ19-700 and ZZ38-700 as an alternate to AZ's? **They will be accepted if they meet or exceed the specification listed. The product section appears to be equivalent to what was specified, but the steel material must be certified to meet the ASTM A 572 Grade 60.**

- 2) Can a 50' sheet be supplied to cover the 41' length, or do they have to be cut down to length? **No they must be cut to length per specifications.**

If you have already sent your bid in and need to make corrections please email any increase or decrease you would like to be made to each line. If you do not wish to make any changes no further action is required.

All other terms and conditions remain unchanged.

If there are any questions regarding this addendum please let me know.

Thank you,

Greg Goemer
Sr. Contract Administrator
Alaska Railroad Corporation