



### ADDENDUM NO. 3

TO: Interested Parties

FROM: Pam Mohn, P.E.  
Chief of Design, Engineering

DATE: Wednesday, May 1, 2019

RE: Back Road Repair  
Contract No. RD-BR-272-10

---

Acknowledge receipt of this Addendum No. 3 by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This Addendum No. 3 forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This Addendum No. 3 consists of 3 pages, including this page and attachments.

I hereby acknowledge receipt of Addendum No. 3:

By: \_\_\_\_\_ Date \_\_\_\_\_  
Signed Name

\_\_\_\_\_  
Typed Name

\_\_\_\_\_  
Title

For: \_\_\_\_\_

**Back Road Repair**  
**County Contract No. RD-BR-272-10**

Date Issued: **Wednesday, May 1, 2019**

Bids Due: **Wednesday, May 8, 2019**  
**2:00 p.m., E.S.T.**

The following addendum material is hereby made a part of the Bid Documents. Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



Pam Mohn, P.E.  
Chief of Design

By Authority of:  
Board of County Commissioners  
Washington County, Maryland



Scott Hobbs, P.E.  
Director of Engineering

**ADDENDUM NO. 3**  
**BACK ROAD REPAIR**  
**County Contract No. RD-BR-272-10**

**TO:** All prime potential bidders.

**ITEM 1.01** **Additional Submitted Inquiries and Responses:**

1. Please clarify Addendum No. 2, responses 1 & 3. Our understanding was that the stream was to be restored to a pre-flood condition, similar to the roadway and structure. The Addendum seems to indicate that the stream work will result in the sediment and nutrient reduction which is significantly more in scope. Creation of a stream BMP will involve pools, vanes, etc.

**Response 1: The stream channel associated with Site 1, approximately 525 LF, shall be restored, with MDE's approval, to a condition that adheres to the NRCS Stream Restoration Design standards and provides sediment and nutrient reduction credits.**

2. We request that a one-week extension be reconsidered in order to better refine the project risk.

**Response 2: The Bid Due Date shall be extended until Wednesday, May 8, 2019 at 2:00p.m., E.S.T.**

**END ADDENDUM NO. 3**