

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Order Instituting Rulemaking to Examine
Electric Utility De Energization of Power
Lines in Dangerous Conditions.

R.18-12-005
(Filed December 13, 2018)

**SAN DIEGO GAS & ELECTRIC COMPANY (U 902-E)
CORRECTIONS TO 2021 PUBLIC SAFETY POWER SHUTOFF POST-SEASON
REPORT AND PUBLIC SAFETY POWER SHUTOFF POST-EVENT REPORT
FOR NOVEMBER 24 – NOVEMBER 26, 2021**

Christopher M. Lyons
San Diego Gas & Electric Company
8330 Century Park Court, #CP32D
San Diego, CA 92123
Telephone: (858) 654-1559
Fax: (619) 699-5027
Email: clyons@sdge.com

Attorney for:
SAN DIEGO GAS & ELECTRIC COMPANY

May 6, 2022

**BEFORE THE PUBLIC UTILITIES COMMISSION
OF THE STATE OF CALIFORNIA**

Order Instituting Rulemaking to Examine
Electric Utility De Energization of Power
Lines in Dangerous Conditions.

R.18-12-005
(Filed December 13, 2018)

**SAN DIEGO GAS & ELECTRIC COMPANY (U 902-E)
CORRECTIONS TO 2021 PUBLIC SAFETY POWER SHUTOFF POST-SEASON
REPORT AND PUBLIC SAFETY POWER SHUTOFF POST-EVENT REPORT
FOR NOVEMBER 24 – NOVEMBER 26, 2021**

In compliance with California Public Utilities Commission Public Safety Power Shutoff (PSPS) Order Instituting Rulemaking Phase 1 Decision (D.) 19-05-042, Phase 2 D.20-05-051, Phase 3 D.21-06-034 and PSPS Order Instituting Investigation D.21-06-014, San Diego Gas & Electric Company (SDG&E) hereby submits corrections to its 2021 PSPS Post-season Report and November 24-26, 2021 Post-event Report.¹

SDG&E hereby provides the following link to access and download the corrected attachments (geodatabase files and Excel workbooks): <https://www.sdge.com/wildfire-safety/pssp-more-info>.

Respectfully submitted,

By: /s/ Christopher M. Lyons
Christopher M. Lyons
San Diego Gas & Electric Company
8330 Century Park Court, #CP32D
San Diego, CA 92123
Telephone: (858) 654-1559
Fax: (619) 699-5027
Email: clyons@sdge.com

Attorney for:
SAN DIEGO GAS & ELECTRIC COMPANY

May 6, 2022

¹ SDG&E's November 24-26, 2021 Post-event report and 2021 Post-season report were filed and served on December 10, 2021 and March 1, 2022, respectively.

Attachment A

**Corrections to 2021 Public Safety Power Shutoff Post-Season Report
And
Public Safety Power Shutoff Post-Event Report
for November 24 – November 26, 2021**

In summary, SDG&E reported a total of 47 medical baseline (MBL) customers de-energized during its November 24-26 PSPS event, but the correct number of MBL customers de-energized was 406. SDG&E identified the discrepancy in preparation of its 2021 Post-season Data Report (PSDR) issued by the Commission’s Safety Enforcement Division (SED) and informed SED of this discrepancy on April 1, 2022.

Corrections to 2021 PSPS Post-Season Report

SDG&E corrected the MBL figures in the two attachments shown below provided in its 2021 PSPS Post-season report and provides the following link to access and download the corrected attachments: <https://www.sdge.com/wildfire-safety/psps-more-info>. They are also being filed with the Commission via CD-ROM.

Attachment 1 – POSTSR 2A: Geospatial PSPS Data by Census Tract (Zipped Geodatabase File)
Attachment 2 – POSTSR 2B: Non-Spatial PSPS Data by Census Tract (Excel File)

The total number of MBL customer accounts de-energized in Column M of POSTSR 2B was corrected as well as the associated geospatial data provided in POSTSR 2A.

Corrections to PSPS Post-Event Report for November 24 – November 26

Section 1 – Executive Summary

Table 1: PSPS Event Summary

Total Customers			De-energized				Number of Circuits			Damage/ Hazard Count
PSPS Notified	De- energized	Cancelled	MBL Customers	Number of Counties	Number of Tribes	Critical Facilities and Infrastructure	Transmission De-energized	Distribution Circuits in Scope	Distribution Circuits De- energized	
54,527	5,858	48,669	47 406	1	5	241	0	79	13	0

Section 3 – De-energized Time, Place, Duration and Customers

- A zipped geodatabase file that includes PSPS event polygons of de-energized areas. The file should include items that are required in Section 3.3.**

A corrected zipped geodatabase file that includes all information in Section 3.3 is included with this filing as Appendix 1 and can also be accessed at: <https://www.sdge.com/wildfire-safety/psps-more-info>. The total number of MBL customers was corrected.

3. A list of circuits de-energized, with the following information for each circuit. This information should be provided in both a PDF and excel spreadsheet.
- County
 - De-energization date/time
 - Restoration date/time
 - “All Clear” declaration date/time
 - General Order (GO) 95, Rule 21.2-D Zone 1, Tier 2, or Tier 3 classification or nonHigh Fire Threat District
 - Total customers de-energized
 - Residential customers de-energized
 - Commercial/Industrial customers de-energized
 - Medical Baseline (MBL) customers de-energized
 - AFN other than MBL customers de-energized
 - Other Customers
 - Distribution or transmission classification

The corrected list of circuits de-energized with the required information is included in Appendix 2 as Table 3 and can also be accessed at: <https://www.sdge.com/wildfire-safety/psps-more-info>. Corrections to the ”MBL Customers” column are shown in redline in Appendix 2.

The field “AFN other than MBL Customers” includes all customers that meet any of the 12 AFN conditions flagged in SDG&E’s customer information system as long as MBL is not the only condition. However, there are 144 instances where the customer has MBL flagged in addition to any of the other 11 AFN conditions.

Section 5 – Notifications

3. For those customers where positive or affirmative notification was attempted, use the following template to report the accounting of the customers (which tariff and/or access and functional needs population designation), the number of notification attempts made, the timing of attempts, who made the notification attempt (utility or public safety partner) and the number of customers for whom positive notification was achieved. “Notification attempts made” and “Successful positive notification” must include the unique number of customer counts. When the actual notification attempts made is less than the number of customers that need positive notifications, the utilities must explain the reason. In addition, the utilities must explain the reason of any unsuccessful positive notifications.

Table 4: Positive Notification

Designation	Total Number of Customers	Notification Attempts Made	Timing of Attempts	Who made the Notification Attempt	Successful Positive Notification
AFN	1,082	1,082	11/23/2021- 11/24/2021	SDG&E	1,082
MBL	47 406	47 406	11/23/2021- 11/24/2021	SDG&E	47 406

Appendix 1 - 2

Appendix 1

Zipped Geodatabase File
PSPS_Event_11242021_DeEnergized_CircuitOutageAreas
(Filed Via CD-ROM)

Appendix 2

Table 3 of PSPS Event Data Workbook (Excel File Filed Via CD-ROM)

Public Safety Power Shutoff Post-Event Report: November 24 – November 26, 2021

Appendix 2: PSPS Event Data Workbook

Table 3: Circuits De-energized

Distribution/Transmission	Circuit/Device Name	County	De-energization Date and Time	Restoration Date/Time	Duration	All clear Date/Time	HFTD Tier	Total Customers	Residential Customers	Commercial/Industrial Customers	MBL Customers	AFN other than MBL Customers ²	Other Customers
Distribution	79-799R	San Diego	11/24/2021 21:53	11/26/2021 15:05	41:12:00	11/26/2021 11:57	Tier 3	19	13	6	0 2	7	N/A
Distribution	79-679R	San Diego	11/25/2021 16:43	11/26/2021 14:43	22:00:00	11/26/2021 11:56	Tier 3	163	140	23	0 9	19	N/A
Distribution	73-678R	San Diego	11/25/2021 5:52	11/26/2021 11:47	29:55:00	11/26/2021 5:58	Tier 3	148	129	19	0 8	20	N/A
Distribution	73-643R	San Diego	11/25/2021 16:48	11/26/2021 11:33	18:45:00	11/26/2021 8:18	Tier 3	384	314	70	3 22	64	N/A
Distribution	73-23R	San Diego	11/25/2021 5:52	11/26/2021 11:54	30:02:00	11/26/2021 5:58	Tier 3	215	188	27	4 15	40	N/A
Distribution	67-45R	San Diego	11/25/2021 7:21	11/26/2021 10:19	26:58:00	11/26/2021 5:58	Tier 3	101	88	13	0 7	18	N/A
Distribution	67-37R	San Diego	11/25/2021 7:21	11/26/2021 10:23	27:02:00	11/26/2021 5:58	Tier 3	81	66	15	0 6	3	N/A
Distribution	67-34R	San Diego	11/25/2021 7:21	11/26/2021 9:06	25:45:00	11/26/2021 5:58	Tier 3	241	213	28	2 27	46	N/A
Distribution	67-24R	San Diego	11/25/2021 7:21	11/26/2021 11:13	27:52:00	11/26/2021 5:58	Tier 3	155	133	22	0 10	22	N/A
Distribution	524-69R	San Diego	11/25/2021 7:42	11/26/2021 9:40	25:58:00	11/26/2021 7:00	Tier 3	404	367	37	5 20	51	N/A
Distribution	524-50R	San Diego	11/25/2021 7:51	11/26/2021 11:31	27:40:00	11/26/2021 5:58	Tier 3	165	141	24	4 18	12	N/A
Distribution	448-23R	San Diego	11/25/2021 4:49	11/26/2021 13:00	32:11:00	11/26/2021 12:03	Tier 3	44	28	16	0	13	N/A
Distribution	448-19R	San Diego	11/25/2021 4:49	11/26/2021 13:09	32:20:00	11/26/2021 12:03	Tier 3	66	56	10	4 2	26	N/A
Distribution	445-897R	San Diego	11/24/2021 22:26	11/26/2021 16:14	41:48:00	11/26/2021 13:20	Tier 2	8	8	0	0 2	2	N/A
Distribution	445-894R	San Diego	11/24/2021 22:26	11/26/2021 15:51	41:25:00	11/26/2021 13:20	Tier 2	166	137	29	2 9	58	N/A

² Includes all customers that meet any of the 12 AFN conditions flagged in SDG&E’s customer information system as long as MBL is not the only condition. However, there are 144 instances where the customer has MBL flagged in addition to any of the other 11 AFN conditions.

Distribution/Transmission	Circuit/Device Name	County	De-energization Date and Time	Restoration Date/Time	Duration	All clear Date/Time	HFTD Tier	Total Customers	Residential Customers	Commercial/Industrial Customers	MBL Customers	AFN other than MBL Customers ²	Other Customers
Distribution	445-39R	San Diego	11/24/2021 22:26	11/26/2021 15:38	41:12:00	11/26/2021 13:20	Tier2	193	157	36	+ 12	56	N/A
Distribution	445-24R	San Diego	11/24/2021 22:26	11/26/2021 16:35	42:09:00	11/26/2021 13:20	Tier 2	166	136	30	0 6	69	N/A
Distribution	445-19R	San Diego	11/24/2021 22:26	11/26/2021 15:46	41:20:00	11/26/2021 13:20	Tier 2	89	74	15	+ 5	22	N/A
Distribution	445-17R	San Diego	11/24/2021 22:26	11/26/2021 15:42	41:16:00	11/26/2021 13:20	Tier 2	160	124	36	2 9	33	N/A
Distribution	445-1311R	San Diego	11/24/2021 22:26	11/26/2021 16:37	42:11:00	11/26/2021 13:20	Tier 2	178	158	20	+ 9	49	N/A
Distribution	358-682F	San Diego	11/25/2021 4:19	11/26/2021 13:20	33:01:00	11/26/2021 10:42	Tier 3	189	167	22	+ 12	45	N/A
Distribution	358-585R	San Diego	11/25/2021 5:20	11/25/2021 14:45	9:25:00	11/26/2021 10:42	Tier 2	168	86	82	2 10	10	N/A
Distribution	357-750R	San Diego	11/25/2021 6:26	11/26/2021 8:51	26:25:00	11/26/2021 5:58	Tier 2	288	272	16	6 32	12	N/A
Distribution	357-50R	San Diego	11/25/2021 8:07	11/25/2021 13:12	5:05:00	11/25/2021 11:16	Tier 2	445	430	15	3 53	35	N/A
Distribution	357-1299R	San Diego	11/25/2021 6:02	11/26/2021 12:07	30:05:00	11/26/2021 9:30	Tier 3	9	8	1	0	0	N/A
Distribution	217-983R	San Diego	11/25/2021 2:23	11/25/2021 12:48	10:25:00	11/25/2021 10:00	Tier 3	77	71	6	+ 5	7	N/A
Distribution	214-647R	San Diego	11/25/2021 3:02	11/25/2021 15:58	12:56:00	11/25/2021 11:05	Tier 3	138	116	22	0 5	46	N/A
Distribution	214-1122R	San Diego	11/25/2021 3:02	11/25/2021 15:33	12:31:00	11/25/2021 11:05	Tier 3	233	181	52	2 11	47	N/A
Distribution	157-232R	San Diego	11/25/2021 5:36	11/26/2021 13:08	31:32:00	11/26/2021 11:59	Tier 3	94	85	9	0 10	34	N/A
Distribution	157-204R	San Diego	11/25/2021 7:38	11/26/2021 13:01	29:23:00	11/26/2021 5:58	Tier 3	368	311	57	4 31	45	N/A
Distribution	157-189R	San Diego	11/25/2021 5:36	11/26/2021 13:17	31:41:00	11/26/2021 11:59	Tier 3	245	173	72	2 8	86	N/A
Distribution	1458-519	San Diego	11/25/2021 5:18	11/25/2021 13:52	8:34:00	11/25/2021 12:56	Tier 2	345	277	68	+ 20	75	N/A
Distribution	1166-342R	San Diego	11/25/2021 5:40	11/26/2021 11:27	29:47:00	11/26/2021 5:58	Tier 3	95	81	14	+ 10	6	N/A
Distribution	1166-18R	San Diego	11/25/2021 5:40	11/26/2021 11:09	29:29:00	11/26/2021 5:58	Tier 3	18	13	5	1	4	N/A