



## ADDENDUM NO. 2

TO: Interested Parties

FROM: Eric Miklosovich,  
Project Manager, Division of Engineering

DATE: Tuesday, April 5, 2022

RE: Mousetown Road Culvert Replacements  
Contract No. BR-MR-212-14  
Project No. 14-212

---

Acknowledge receipt of this **Addendum No. 2** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This Addendum No. 2 forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 2** consists of 3 pages, including this page and attachments.

I hereby acknowledge receipt of Addendum No. 2:

By: \_\_\_\_\_ Date \_\_\_\_\_  
Signed Name

\_\_\_\_\_  
Typed Name

\_\_\_\_\_  
Title

For: \_\_\_\_\_  
Firm

80 West Baltimore Street | Hagerstown, MD 21740-6003 | P: 240.313.2460 | TDD: 711

**ADDENDUM NO. 2**

**Mousetown Road Culvert Replacements  
Contract No. BR-MR-212-14  
Project No. 14-212**

Date Issued: April 5, 2022

Bids Due: April 20, 2022  
11:00am


The following addendum material is hereby made a part of the Bid Documents. Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



---

Eric Miklosovich  
Project Manager  
Division of Engineering

By Authority of:  
Board of County Commissioners  
Washington County, Maryland



---

Scott Hobbs, P.E.  
Director  
Division of Engineering

## **ADDENDUM NO. 2**

### **Mousetown Road Culvert Replacements Contract No. BR-MR-212-14 Project No. 14-212**

**To:** Interested Parties

**Item 1.01** **QUESTIONS THAT WERE SUBMITTED BY FRIDAY, April 1, 2022 (4:00 PM):** shall be incorporated into the Bid Documents.

#### **Question 1 – Brawner Builders:**

It is noted in paragraph two on Page ITB-3 of the Invitation to Bid for this solicitation that the value of this contract is anticipated to fall within the SHA Cost Group Class “B”, \$100,001 to \$500,000. Based on our cursory review of the scope of work included in this solicitation, we anticipate the value of this contract to be in excess of \$1,000,000. We are concerned that receipt of a low bid in excess of the Class “B” cost group may result in rejection of all bids. Please confirm the County’s Engineer’s Estimate for the anticipated value of this Contract.

#### **Response:**

The Engineers estimate falls within SHA Cost Group Letter Class “C,” \$500,001 to \$1,000,000.

**Item 1.02** **Clarification:**

A mastic seal will be required over the 2” non-shrink grout, mastic shall be a 2-ply membrane waterproofing 16” minimum centered on gap connecting the two box culverts.

**END ADDENDUM No. 2**