



DIVISION OF PUBLIC WORKS
BUILDINGS, GROUNDS & FACILITIES | HIGHWAYS | PARKS & RECREATION | TRANSIT

ADDENDUM NO. 1

TO: Interested Parties

FROM: Andrew Eshleman, Director, Public Works
Division of Engineering

DATE: Wednesday, April 29, 2020

PROJECT: **GARIS SHOP WATER TRAIL FENCE AND GATE**

Acknowledge receipt of this **Addendum No. 1** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 1** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 1** consists of 3 pages, including this page.

I hereby acknowledge receipt of **Addendum No. 1**:

By: _____ Date _____

Signed Name

Typed Name

Title

For (Firm): _____

Phone Number: _____

ADDENDUM NO. 1
Page 1 of 3

ADDENDUM NO. 1

GARIS SHOP WATER TRAIL FENCE AND GATE

Date Issued: Wednesday, April 29, 2020

Bids Due: **Friday, May 1, 2020**
4:00 p.m., Local Time

The following addendum material is hereby made a part of the Bid Documents.

Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.

By Authority of:
Board of County Commissioners
Washington County, Maryland



Andrew Eshleman, P.E.
Director
Division of Public Works

ADDENDUM NO. 1

GARIS SHOP WATER TRAIL FENCE AND GATE

TO: All prime Contractors and all others to whom specifications have been issued.

ITEM 1.01 **BID QUESTIONS & RESPONSES**, received by the deadline on April 28, 2020:

1.01. The Fiberon fence has been discontinued in manufacturing.

Response: In lieu of being able to securing available remaining fiberon fence, an alternate vinyl ranch rail fence is specified.

Alternate Fence Specification

Vinyl three rail ranch fence, 8 ft maximum section. Minimum 4 ft. height. Color – white.
5” square posts.

END OF ADDENDUM NO. 1