

ADDENDUM NO. 1

TO: Interested Parties

FROM: Brennan Garrett, Senior Architectural Project Manager
Division of Engineering

DATE: Monday, April 27, 2020

PROJECT: **OPERABLE PARTITIONS FOR BOARD OF ELECTIONS FACILITY**

Acknowledge receipt of this **Addendum No. 1** by signing in the space provided below and returning with your Bid.

Failure to sign and return with your Bid may subject the Bidder to disqualification. This **Addendum No. 1** forms a part of the Bid Documents, it supplements and modifies them as outlined herein.

This **Addendum No. 1** consists of 3 pages, including this page.

I hereby acknowledge receipt of **Addendum No. 1**:

By: _____ Date _____

Signed Name

Typed Name

Title

For (Firm): _____

Phone Number: _____

ADDENDUM NO. 1


OPERABLE PARTITIONS FOR BOARD OF ELECTIONS FACILITY

Date Issued: Monday, April 27, 2020

**Bids Due: Thursday, April 30, 2020
4:00 p.m., Local Time**


The following addendum material is hereby made a part of the Bid Documents.

Please note the following changes, information, and/or instructions in connection with the proposed work and submit proposals accordingly.



Brennan Garrett
Senior Architectural Project Manager
Division of Engineering

By Authority of:
Board of County Commissioners
Washington County, Maryland



Scott Hobbs, P.E.
Director
Division of Engineering

ADDENDUM NO. 1

OPERABLE PARTITIONS FOR BOARD OF ELECTIONS FACILITY

TO: All prime Contractors and all others to whom specifications have been issued.

ITEM 1.01 Quotation Due Date Clarification:

QUOTATION DUE: Thursday, April 30, 2020, no later than 4:00 P.M. by e-mail (ecquotes@washco-md.net), fax (240-313-2401), or delivered.

ITEM 1.02 Clarification:

Please note that the required Sound Transmission Class (STC) rating for the specified operable partitions has been revised to a minimum STC of 41.

END OF ADDENDUM NO. 1